(ख) यदि हां, तो ग्रीष्मकाल के दौरान दिल्ली के निवासियों की पानी की दैनिक आवश्यकता कितनी है तथा वर्तमान व्यवस्था के आधार पर कुल कितना पानी उपलब्ध हो पाता है; और

(ग) क्या यह सच है कि उचित ढंग से पानी का इस्तेमाल न किए जाने, पानी के रिसाव तथा उसकी दोषपूर्ण वितरण प्रणाली के कारण 25 प्रतिशत से 30 प्रतिशत तक पेयजल बर्बाद हो जाता है और यदि हां, तो पेयजल की वर्तमान बर्बादी को रोकने के लिए क्या तत्काल उपाय किए जा रहे हैं ?

शहरी विकास मंत्री (श्रीमती मोहसिना किदवई) : (क) और (ख) दिल्ली जल-पूर्ति तथा मल व्ययन संस्थान 472 एम०जी० की निर्धारित आवश्यकता की तुलना में 410 एम०जी०डी० पानी का उत्पादन करने हेतु सज्जित है । दो रैनी कुएं, 25 नलकूपों को स्थापित करके तथा विद्यमान जल शोधन संयंत्रों की क्षमता को अधिकतम करके पानी के उत्पादन को 445 एम०जी०डी० तक बढ़ाने के उपाय किए गए हैं ।

(ग) वितरण पद्धति में रिसाव और अनुचित उपयोग के कारण हुई हानि का अनुमान 15 प्रतिशत से 20 प्रतिशत लगाया जाता है । उचित उपयोग तथा पेयजल पूर्ति की बरबादी को रोकने को सुनिश्चित करने के लिए निम्नलिखित उपाय किए जा रहे हैं :

(I) स्वच्छ जल को बागवानी से पेय प्रयोजनों की ओर परिवर्तित करना ।

(II) सार्वजनिक नलों का बहतर प्रबन्ध।

(III) वितरण पद्धति में रिसाव का नियंत्रण ।

(Iv) वितरण पद्धति का नियंत्रण ।

(v) पेयजल के उचित उपयोग के बारे में जनता को शिक्षित करना ।

Supply of water in Netaji **Nagar** New Delhi

1302. PROF. C. LAKSHMANNA Will the Minister of URBAN DEVELOPMENT be pleased to refer to the reply to Unstarred Question 2775 given in the Rajya Sabha on the 17th March, 1989 and state:

(a) whether the work of interconnecting the water pipe lines for the improvement of water supply to E-Block Extension, Netaji Nagar, New Delhi particularly the upper storey quarters from E-1141 to E-1182, has since been completed;

(b) if so, what are the reasons that the water supply has not actually improved;

(c) if the answer to part (a) above be in negative how much more time it would take to inter-connect the water, lines and improve the water supply; and

(d) what are the reasons that the: water is not being supplied regularly through tankers uptill the time, the scheme is complete as has been promised?

THE MINISTER OF URBAN DEVELOPMENT (SHRIMATI MOHSINA KIDWAI): (a) Yes, Sir.

(b) and (c) After the inter-connection work there is appreciable improvement of water supply in these Blocks except for the first floor flats from E-1141 to E-l 182 where the pressure has been found to below. A Pressure Survey of these flats is being carried out and necessary remedial measures will be taken within 2-3 weeks time.

(d) Water is being supplied regularly by New Delhi Municipal Committee as and when any requisition is received from individuals.